

**Example: Einsteinville Plant Store Facility
Fire and Explosion EAL**

Classification	Criteria, Means, Indicators	Action
Operations Emergency (Not further classified)	Smoke AND heat detector annunciation	<ul style="list-style-type: none"> • Evacuate building • Dispatch FD to investigate
Alert	<ul style="list-style-type: none"> • Smoke AND heat detector annunciation PLUS • Visible smoke OR fire suppression system activation 	<ul style="list-style-type: none"> • Evacuate building • Isolate event scene • Shelter downwind • Activate ERO
Site Area Emergency	Fire breaches the building	<ul style="list-style-type: none"> • Evacuate building • Shelter-in-place the remainder of the plant • Activate ERO
General Emergency	<ul style="list-style-type: none"> • Fire breaches the building AND • Is at OR threatening the chemical cylinder storage in the loading dock area 	<ul style="list-style-type: none"> • Evacuate building • Shelter-in-place remainder of the plant • Activate ERO • Recommend offsite shelter-in-place downwind of the event